

*Town of Fairhaven  
Board of Public Works*

*5 Arsene Street  
Fairhaven, Massachusetts 02719*

*TEL. 508-979-4030  
FAX. 508-979-4086  
bpw@fairhaven-ma.gov*



To: Paul Foley, Director Planning & Economic Development  
From: Vincent D. Furtado, BPW Superintendent  
Date: October 31, 2019  
Re: SP 2019-14: Carricorp Bridge Street Gas Station Modifications

The Board of Public Works has the following comment regarding Carricorp Bridge Street Gas Station Modifications.

Highway: 1. First Defense Model FD-3HC is not an approved equal see GCG Review (attached to email dated 10/28/2019).  
2. Where is the plan showing the new layout for potential bike lane?

Sewer: No Comments

Water: No Comments